



CLIV.R38040 Wall-opening Protective Materials

[Page Bottom](#)

Wall-opening Protective Materials

[See General Information for Wall-opening Protective Materials](#)

STC ARCHITECTURAL PRODUCTS L L C

R38040

1200 NORTHLAND AVE
BUFFALO, NY 14215 USA

STC box seals for use with max 4-by 4 by 1-1/4 in. flush device UL Listed Metallic Outlet Boxes installed with steel mud rings and steel cover plates with one-gang duplex receptacle in 1 h fire rated gypsum board wall assemblies framed with min 3-5/8 in. deep steel studs and constructed of the materials and in the manner specified in the individual U400, V400 or W400 Series Wall and Partition Designs in the Fire Resistance Directory. One 4-1/2 by 2-3/4 in. box seal installed under the receptacle faceplate. Installation to comply with the National Electrical Code (NFPA 70). Boxes may be installed within the same stud cavity or back-to-back provided there is no inter-connection between the boxes.

[Last Updated](#) on 2016-01-08

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".